

State License No. C57 432680
P.O. BOX 845
ATASCADERO, CA 93423
805-466-1271

Name KEN JEVEC
Mailing Address 1176 AGUA CALIENTE CT. - MINDEN, NV 89423
Job Location 3760 HWY 46 WEST
Well Size 5" Depth 700'
Tested by N.THOMPSON Rate of Flow (gpm) 15

Date 7/22/2021
Phone _____
APN 040-231-016
Duration 4 HOUR
Static Level 206'

Well Test Report

<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>	<u>G.P.M.</u>	<u>Drawdown</u>
<u>7/21/2021</u>	<u>9:15AM</u>	<u>206'</u>	<u>17.6</u>	
	<u>9:20</u>		<u>17.6</u>	
	<u>9:25</u>		<u>17.6</u>	
	<u>10:15</u>		<u>17.6</u>	
	<u>10:45</u>		<u>15.0</u>	
	<u>11:15</u>		<u>15.0</u>	
	<u>11:45</u>		<u>15.0</u>	
	<u>12:15PM</u>		<u>15.0</u>	
	<u>12:45</u>		<u>15.0</u>	
	<u>1:15</u>		<u>15.0</u>	

Recovery


<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>
-------------	-------------	-------------------------

Additional Comments:

TECHNICIAN WAS UNABLE TO GET WATER LEVELS AS SOUNDER WOULD NOT GO DOWN WELL

Thank you,

Ned M. Thompson



State License No. C57 432680
P.O. BOX 845
ATASCADERO, CA 93423
805-466-1271

PUMP INSTALLATION REPORT

Name KEN JEVEC Date 7/5/2016
Address 1176 AGUA CALIENTE CT. - MINDEN, NV 89423 Code 29/69
Location 3760 HWY 46 WEST Well # 2016 Phone 238-5634
APN 040-231-016

PUMP

Make GOULDS Model # 10GS20
H.P. 2 Serial # M1538363 Voltage 230 VOLT / SINGLE PHASE
Pipe size 1 1/4" Type PVC SCH 120 SS COUP Wire size #8/4 Type FLAT JACKET
Depth Setting 500' Well Seal 5" X 1 1/4" Check Valve PUMP & 1/2 WAY
Motor Date 15K14-22-00999C Motor Model # 2243019204
Motor Serial # 326985902 Safety Rope 1/2"
Booster Pump Make Model #
Misc.

CONTROL

Control box 2 HP Make FRANKLIN
Pressure Switch SQUARE D On Lbs. Off Lbs.
Liquid Level 233 PUMPSAVER Low X High X SOLENOID
Relief Valve Make Setting
Pump Panel Make Voltage Mag Size
Heater/Overload Fuses
Misc.

STORAGE

Size Galv ☐ Poly ☐ Fiberglass ☐
Pressure Tank Make Size Model
Misc.

WELL

Casing Size 5" Type PVC
Depth To Water 206' (7/21/21) To Bottom 700' WCR#2016-003300 (5/6/16)
G.P.M. @ Ft. Tested By
Misc.

Abalone Coast Analytical, Inc.

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1075

Order #: 21-3535

Date/Time Rec'd: 7/22/21 1522

Filippini & Thompson Drilling

P.O. Box 845

Atascadero, CA 93423

Contact: Ned Thompson

Phone: 805-466-1271

Sampler:

Project: Ken Jevac

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	3760 Hwy 46 West	7/21/21 1300	MPN Total Coliform	SM 9223 B.	10.	MPN/100mL	1	07/23/21
	Templeton		MPN E-coli	IDEXX	ND.	MPN/100mL	1	07/23/21

Report Completion Date:

7/23/21

Reviewed By:



Amanda Smith, Lab Director

Definitions:

MPN = Most Probable Number

RL = Reporting Limit

ND = Analyte NOT DETECTED at or above MDL

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.