

WOOD STOVE AND FLUE PIPE, page 2

CLEARANCES, cont'd	ACTUAL	REQ'D	CODE COMPLIANCE, cont'd
5. Shielding			<input checked="" type="checkbox"/> N/A <input type="checkbox"/> No <input type="checkbox"/> Yes
6. Ember pad size/material			<input type="checkbox"/> N/A <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
7. Heat protection: floor			<input type="checkbox"/> N/A <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes <input type="checkbox"/> UTI
FLUE PIPE TYPE: <input type="checkbox"/> Single wall <input checked="" type="checkbox"/> Double wall Size: 6" Required Clearance: 9"			
8. Clearances	10"	9"	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
9. Total length	4ft		<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
10. Elbows	1		<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
11. Fastening	yes		<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes
12. Expansion joint if vertical			<input checked="" type="checkbox"/> N/A <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> UTI
13.			<input checked="" type="checkbox"/> N/A <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> UTI
14.			<input checked="" type="checkbox"/> N/A <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> UTI
15. Connection to breech pipe			<input type="checkbox"/> N/A <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes <input type="checkbox"/> UTI
16. Connection to FB chimney			<input type="checkbox"/> N/A <input checked="" type="checkbox"/> No <input checked="" type="checkbox"/> Yes <input type="checkbox"/> UTI
OTHER CONSIDERATIONS		CODE COMPLIANCE	
17. Alcove approved <input type="checkbox"/> No <input type="checkbox"/> Yes		<input checked="" type="checkbox"/> N/A <input type="checkbox"/> No <input type="checkbox"/> Yes	
18. Mobile home approved <input type="checkbox"/> No <input type="checkbox"/> Yes		<input checked="" type="checkbox"/> N/A <input type="checkbox"/> No <input type="checkbox"/> Yes	
19. Outdoor air connection <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes Required? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes		<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes <input type="checkbox"/> UTI	
20.			
Photos taken: <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes Your file reference: 2030 Lilac			

Comments and Observations. All non-compliance ratings should be considered for comment. Please attach an additional page(s) for this section.

This checklist contains 3 pages in total. The Inspection Report contains 3 pages in total.

Inspector Signature: **Glenn Dilts**
Digitally signed by Glenn Dilts
 Date: 2020.10.09 06:53:51 -04'00'
 Date: 09/17/2020

AmeriSpec of Barrie, Orillia, Muskoka & Collingwood

Client Name: Anthony Cotroneo Level of Inspection: Level 1 Level 2 Level 3

Comments and Observations. *All non-compliance ratings should be considered for comment.
Attach additional files if needed.*

RECOMMEND TO HAVE THE STOVE AND CHIMNEY CLEANED ANNUALLY.
RECOMMEND TO HAVE CARBON MONOXIDE DETECTOR IN ALL APPROPRIATE LOCATION IN THE HOME.

This checklist contains 3 pages in total. The Inspection Report contains 3 pages in total.

Inspector Signature: **Glenn Dilts**
*Digitally signed by Glenn Dilts
Date: 2020.10.09 06:56:12 -04'00'*

Date: **09/17/2020**

AmeriSpec of Barrie, Orillia, Muskoka & Collingwood