

Abalone Coast Analytical, Inc
141 Suburban Road, Suite C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1075
ELAP #2661

Order #: 24-2784
Date/Time Rec'd: 6/27/24 0832

Bailey Drilling
1191 MTN Spring Rd
Paso Robles CA 93446


Contact: Mike Schmitz
Phone: 459-4266
Sampler: Mike Schmitz

Project: Louis Cyn

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	San Miguel CA	6/26/24 1300	Total Coliform	SM 9223 B.	Absent	/100ml	1	06/28/24
			E-coli	IDEXX	Absent	/100ml	1	06/28/24

These samples pass water quality standards for Total Coliform and E. Coli Bacteria

Report Completion date: 6/28/24

Reviewed: 
Priyanka Singh, Technical Director

Definitions:

Absent = Less than 1 CFU/100mLs

Present = 1 or more CFU/100mLs

CFU = Colony Forming Unit


RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

Bailey Drilling & Pump



Pump Test Report

Well Owner _____

Billing Address: LOW 3 CYN

Pump Set 1 1/2 HP 300'

Pump Size 1 1/2 HP

Well Depth 320'

Totalizer

Start _____

Finish _____

Testing Method: ☒ Bucket

☐ Totalizer

Standing Level Before Testing 189'

APN/Location _____

Time	Pumping Level	GPM	Water Condition
8:30	189'	16.7	clean
8:33	193' 4"	16.7	clean
8:43	194'	16.7	"
9:00	194' 5"	16.7	"
9:15	194' 5"	16.7	clean
9:30	194' 8"	16.7	"
9:45	194' 8"	16.7	"
10:00	194' 9"	16.7	"
10:15	194' 10"	16.7	clean
10:30	195'	16.5	"
10:45	195'	16.0	"
11:00	195'	16.0	"
11:15	195'	16.0	clean
11:30	195' 1"	16.0	"
11:45	195' 1"	16.0	"
12:00	195' 1"	16.0	"
12:15	195' 1"	16.0	clean
12:30	195' 2"	16.0	clean

Time	Pumping Level	GPM	Water Condition

Recovery Level	Time
195' 2"	12:30
192' 4"	12:31
191' 9"	12:32
191'	12:35
190' 9"	12:40
190' 6"	12:45

Recovery Level	Time

Well Produced: 16.0 GPM For 4

Hours on Date 6-26-2024

Test Ran By: M A Schmitz

IT IS UNDERSTOOD THAT BAILEY DRILLING & PUMP INC. WILL NOT BE HELD RESPONSIBLE SHOULD DAMAGE OCCUR TO THE PUMP/WELL WHILE UNDERGOING NORMAL TESTING PROCEDURE.

MIKE A. SCHMITZ
 GENERAL ENGINEERING
 LIC #830412
 1191 MTN. SPRINGS RD.
 PASO ROBLES CA, 93446

Invoice

DATE	INVOICE #
7/1/2024	125

BILL TO
WADE TAYLOR LOWES CANYON

DUE DATE	P.O. NUMBER
7/31/2024	

ITEM	DESCRIPTION	QTY	RATE	AMOUNT
4 hour pump test WATER ANALYSIS	WITH GROUP 1 WATER ANALYSIS INSTALL AND REMOVE TEST PUMP WITH GENERATOR. GROUP 1	1	1,450.00	1,450.00
		1	450.00	450.00
	PLEASE MAKE ALL CHECKS PAYABLE TO: MIKE SCHMITZ 1191 MTN. SPRINGS RD. PASO ROBLES CA 93446			0.00
		Subtotal		1,900.00
		7.5% Tax		
		Total		1,900.00