

**GASTON COUNTY SEPTIC TANK INSPECTION RECORD  
ENVIRONMENTAL HEALTH DIVISION**

S.T. ID # \_\_\_\_\_

CODE/SUB 11

DATE: 10/1/96

Owner Name: Robert Haynes  
Address: 240 Atty Rd  
City/St.: Gastonia N.C.  
Zip: \_\_\_\_\_  
Prev. Owner: \_\_\_\_\_

No. of Tanks: 1 Cap: 1000  
No. of Tanks: 1 Cap: 1000  
Type Sewer System: III-B (Sand, Pump)  
Site Class: AS. (S, PS, N)  
WATER SYSTEM #: \_\_\_\_\_

SEPTIC TANK I.D. #: N/A  
Date Installed: 10/1/96  
Improve. Permit #: 12349  
Type Dwelling: Home  
No. of Bedrooms: 2  
# Users/Tot. People: 4  
Garbage Disposal: N (Y/N)  
Basement N Plumbing: N (Y/N)  
Est. Daily Flow: \_\_\_\_\_

Sys. Name: \_\_\_\_\_  
Loc/SubDiv.: End of Atty Rd on L  
on River

Type Well: C Lot # \_\_\_\_\_ Block # \_\_\_\_\_  
Lot Area: 4 Ac  
Contractor: Stanley PH # \_\_\_\_\_  
Precast Contractor: Dellinger

No. of Trenches: <u>2</u>	Sq. Ft.: <u>600</u>	Lin. Ft.: <u>200</u>	Width: <u>36"</u>	Max. Depth: <u>36"</u>
[Repair] # Trenches: _____	Sq. Ft.: _____	Lin. Ft.: _____	Width: _____	Max. Depth: _____
Sep. Trench/Wash: _____	Sq. Ft.: _____	Lin. Ft.: _____	Width: _____	Max. Depth: _____
Depth of Stone: <u>12"</u>	Other Materials: _____			



Tax Book #: 13 Tax Map #: 93 Tax Parcel #: 21.05

Code #: 11 X Coordinates: \_\_\_\_\_ Y Coordinates: \_\_\_\_\_

(A) Public Comm. (B) Public Non-Comm. ☒ (C) Priv. (D) Comm. (E) Municipal (S8)  
S9

IP Issued By: Jason Conrad Inspected By: M. J. [Signature] R.S.

## LOCATION



(X) m "

HOUSE SEWER: \_\_\_\_\_ feet from right, left, front, rear corner.

SEPTIC TANK: Front, rear right side, left side of building.  
Perpendicular, parallel, angle \_\_\_\_\_ feet from building.

DISTRIBUTION BOX: \_\_\_\_\_ feet from end, side, corner of septic tank.

NITRIFICATION FIELD OR FILTER: \_\_\_\_\_ feet from building at nearest point.

WELL (IF ANY): 76' feet from septic tank  
and 100' feet from disposal field.

SOIL APPEARANCE: Suitable, Provisionally suitable

REMARKS: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_