



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

Laboratory Report

Catherine Harrison
5 Longwood Drive
Hopkinton, MA 01748

Date Printed: 11/13/2024
Work Order #: 2411-00348
Client Job #:
Date Received: 11/04/2024
Sample collected in: Massachusetts

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: H = Hold time non-compliant., L = Laboratory control sample outside control limits.**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/13/2024
CLIENT NAME: Catherine Harrison
CLIENT ADDRESS: 5 Longwood Drive
Hopkinton, MA 01748

SAMPLE ID #: 2411-00348-001
SAMPLED BY: Kim Foemmel

SAMPLE ADDRESS: Harrison
5 Longwood Drive
Hopkinton MA 01748

MORE LOC INFO: Upstairs Master Bathroom

DATE AND TIME COLLECTED: 11/04/2024 12:15PM
DATE AND TIME RECEIVED: 11/04/2024 01:39PM
ANALYSIS PACKAGE: M-Hopkinton
RECEIPT TEMPERATURE: 15.9° CELSIUS

CLIENT JOB #:

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚡

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Turbidity*	<0.5	NTU			0.5	No Limit	EPA 180.1	AH-MA	11/04/2024 02:12PM
Cadmium*	<0.002	mg/L	✓		0.002	0.005 mg/L	EPA 200.7	PF-MA	11/05/2024 05:45PM
Calcium*	46	mg/L			1	No Limit	EPA 200.7	PF-MA	11/05/2024 05:45PM
Copper*	0.122	mg/L	✓		0.010	1.3 mg/L	EPA 200.7	PF-MA	11/05/2024 05:45PM
Iron*	<0.010	mg/L	✓		0.010	0.3 mg/L	EPA 200.7	PF-MA	11/05/2024 05:45PM
Magnesium	4.7	mg/L			1.0	No Limit	EPA 200.7	PF-MA	11/05/2024 05:45PM
Manganese*	<0.010	mg/L	✓		0.010	0.05 mg/L	EPA 200.7	PF-MA	11/05/2024 05:45PM
Potassium	1.7	mg/L		L	1.0	No Limit	EPA 200.7	PF-MA	11/05/2024 05:45PM
Sodium*	23.7	mg/L	✗		1	20 mg/L	EPA 200.7	PF-MA	11/05/2024 05:45PM
Arsenic*	<0.001	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	NM-NH	11/08/2024 02:53PM
Lead*	<0.001	mg/L	✓		0.001	0.015 mg/L	EPA 200.8	NM-NH	11/08/2024 02:53PM
Mercury*	<0.0001	mg/L	✓		0.0001	0.002 mg/L	EPA 200.8	JP-NH	11/12/2024 12:42PM
Chloride*	66.6	mg/L	✓		2	250 mg/L	EPA 300.0	AH-MA	11/04/2024 04:58PM
Fluoride*	1.87	mg/L	✓		0.2	4.0 mg/L	EPA 300.0	AH-MA	11/04/2024 04:58PM
Nitrate as N*	3.64	mg/L	✓		0.05	10 mg/L	EPA 300.0	AH-MA	11/04/2024 04:58PM
Nitrite as N*	<0.05	mg/L	✓		0.05	1 mg/L	EPA 300.0	AH-MA	11/04/2024 04:58PM
Sulfate*	13.6	mg/L	✓		2	250 mg/L	EPA 300.0	AH-MA	11/04/2024 04:58PM
Sediment	Absent						N/A N/A	AH-MA	11/04/2024 02:08PM
Color, Apparent	0	CU	✓		0	15	SM 2120B	KW-MA	11/04/2024 02:11PM
Odor	0	TON	✓		0	3 T.O.N.	SM 2150B	AH-MA	11/04/2024 02:08PM
Total Alkalinity*	91	mg CaCO3/L			5	No Limit	SM 2320B	KW-MA	11/04/2024 04:55PM
Hardness (calc.)	134	mg CaCO3/L			1	No Limit	SM 2340 B	PF-MA	11/05/2024 05:45PM
Specific Conductance @ 25°C	444	umhos/cm			10	No Limit	SM 2510B	KW-MA	11/04/2024 02:16PM
Residual Free Chlorine*	<0.2	mg/L	✓	H	0.2	4	SM 4500Cl-G	KW-MA	11/04/2024 02:21PM

Total Coliform / E.coli Bacteria Preparation (Colilert®-18) 22nd ED SM 9223B ES-MA 11/04/2024 03:09PM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/13/2024
CLIENT NAME: Catherine Harrison
CLIENT ADDRESS: 5 Longwood Drive
Hopkinton, MA 01748

SAMPLE ID #: 2411-00348-001
SAMPLED BY: Kim Foemnel

SAMPLE ADDRESS: Harrison
5 Longwood Drive
Hopkinton MA 01748

MORE LOC INFO: Upstairs Master Bathroom

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

DATE AND TIME COLLECTED: 11/04/2024 12:15PM

DATE AND TIME RECEIVED: 11/04/2024 01:39PM

ANALYSIS PACKAGE: M-Hopkinton

RECEIPT TEMPERATURE: 15.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
pH at 25°C*	7.22	SU	✓	H	N/A	6.5 - 8.5 SU	SM 4500-H-B	KW-MA	11/04/2024 02:16PM
Ammonia as N	<0.1	mg/L			0.1	No Limit	SM 4500NH3 D	MR-MA	11/06/2024 04:30PM
Coliform Bacteria*	Absent	P-A/100mL	✓		Absent	No Limit	SM 9223B	ES-MA	11/05/2024 09:27AM
E. coli Bacteria*	Absent	P-A/100mL	✓		Absent	Absent	SM 9223B	ES-MA	11/05/2024 09:27AM
Total Coliform / E.coli Bacteria Preparation (Colilert®-18) 22nd ED							SM 9223B	ES-MA	11/04/2024 03:09PM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/13/2024
CLIENT NAME: Catherine Harrison
CLIENT ADDRESS: 5 Longwood Drive
Hopkinton, MA 01748

SAMPLE ID #: 2411-00348-002
SAMPLED BY: Kim Foemnel

SAMPLE ADDRESS: Harrison
5 Longwood Drive
Hopkinton MA 01748

MORE LOC INFO: Upstairs Master Bathroom

DATE AND TIME COLLECTED: 11/04/2024 12:15PM
DATE AND TIME RECEIVED: 11/04/2024 01:39PM
ANALYSIS PACKAGE: M-VOC524.2-MA
RECEIPT TEMPERATURE: 15.9° CELSIUS

CLIENT JOB #:

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
1,1,1,2-Tetrachloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,1,1-Trichloroethane*	<0.5	ug/L	✓		0.5	200 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,1,2,2-Tetrachloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,1,2-Trichloroethane*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,1-Dichloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,1-Dichloroethylene*	<0.5	ug/L	✓		0.5	7 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,1-Dichloropropylene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2,3-Trichlorobenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2,3-Trichloropropane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2,4-Trichlorobenzene*	<0.5	ug/L	✓		0.5	70 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2,4-Trimethylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2-Dibromo-3-chloropropane	<0.5	ug/L			0.5	0.2 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2-Dibromoethane	<0.5	ug/L			0.5	0.05 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2-Dichlorobenzene*	<0.5	ug/L	✓		0.5	600 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2-Dichloroethane*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2-Dichloropropane*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,3,5-Trimethylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,3-Dichlorobenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,3-Dichloropropane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,4-Dichlorobenzene*	<0.5	ug/L	✓		0.5	5.0 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
2,2-Dichloropropane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
2-Butanone (MEK)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
2-Chlorotoluene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
2-Hexanone	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/13/2024
CLIENT NAME: Catherine Harrison
CLIENT ADDRESS: 5 Longwood Drive
Hopkinton, MA 01748

SAMPLE ID #: 2411-00348-002
SAMPLED BY: Kim Foemnel

SAMPLE ADDRESS: Harrison
5 Longwood Drive
Hopkinton MA 01748

MORE LOC INFO: Upstairs Master Bathroom

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

DATE AND TIME COLLECTED: 11/04/2024 12:15PM
DATE AND TIME RECEIVED: 11/04/2024 01:39PM
ANALYSIS PACKAGE: M-VOC524.2-MA
RECEIPT TEMPERATURE: 15.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
4-Chlorotoluene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
4-Isopropyltoluene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
4-Methyl-2-pentanone (MIBK)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Acetone	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Benzene*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Bromobenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Bromochloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Bromodichloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Bromoform*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Bromomethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Carbon disulfide	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Carbon tetrachloride*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Chlorobenzene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Chloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Chloroform*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Chloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
cis-1,2-Dichloroethylene*	<0.5	ug/L	✓		0.5	70 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
cis-1,3-Dichloropropylene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Dibromochloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Dibromomethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Dichlorodifluoromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Diethyl ether	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Diisopropyl ether (DIPE)	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Ethyl tert-butyl ether (ETBE)	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/13/2024
CLIENT NAME: Catherine Harrison
CLIENT ADDRESS: 5 Longwood Drive
Hopkinton, MA 01748

SAMPLE ID #: 2411-00348-002
SAMPLED BY: Kim Foemnel

SAMPLE ADDRESS: Harrison
5 Longwood Drive
Hopkinton MA 01748

MORE LOC INFO: Upstairs Master Bathroom

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

DATE AND TIME COLLECTED: 11/04/2024 12:15PM

DATE AND TIME RECEIVED: 11/04/2024 01:39PM

ANALYSIS PACKAGE: M-VOC524.2-MA

RECEIPT TEMPERATURE: 15.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Ethylbenzene*	<0.5	ug/L	✓		0.5	700 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Hexachlorobutadiene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Isopropylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
m&p-Xylenes	<1	ug/L			1	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Methyl tert-butyl ether (MtBE)*	<0.5	ug/L	✓		0.5	70 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Methylene chloride*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Naphthalene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
n-Butylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Nitrobenzene	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
n-Propylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
o-Xylene	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
sec-Butylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Styrene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
tert-Amyl methyl ether (TAME)	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
tert-Butyl alcohol (TBA)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
tert-Butylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Tetrachloroethylene*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Tetrahydrofuran (THF)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Toluene*	<0.5	ug/L	✓		0.5	1000 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Total THMs*	<0.5	ug/L	✓		0.5	80 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
Total Xylenes*	<0.5	ug/L	✓		0.5	10000 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
trans-1,2-Dichloroethylene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
trans-1,3-Dichloropropylene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Trichloroethylene*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/13/2024
CLIENT NAME: Catherine Harrison
CLIENT ADDRESS: 5 Longwood Drive
Hopkinton, MA 01748

SAMPLE ID #: 2411-00348-002
SAMPLED BY: Kim Foemnel

SAMPLE ADDRESS: Harrison
5 Longwood Drive
Hopkinton MA 01748

MORE LOC INFO: Upstairs Master Bathroom

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

DATE AND TIME COLLECTED: 11/04/2024 12:15PM
DATE AND TIME RECEIVED: 11/04/2024 01:39PM
ANALYSIS PACKAGE: M-VOC524.2-MA
RECEIPT TEMPERATURE: 15.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Trichlorofluoromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	11/08/2024 12:30AM
Vinyl chloride*	<0.5	ug/L	✓		0.5	2 ug/L	EPA 524.2	KV-NH	11/08/2024 12:30AM
1,2-Dichlorobenzene-d4	94	%	✓		0.5	70-130%	EPA 524.2 - SS	KV-NH	11/08/2024 12:30AM
4-Bromofluorobenzene	96	%	✓		0.5	70-130%	EPA 524.2 - SS	KV-NH	11/08/2024 12:30AM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

2411-0348

Water Sampling Instructions

PAID
11/4/24

Samples for microbiological analysis must be collected in disposable pre-sterilized plastic bottles. Chemical analysis will be performed from a clean 500mL glass or plastic container.

****PLEASE FILL ALL THE CONTAINERS THAT YOU ARE GIVEN.****

When the sample is collected, sufficient air space (1/4 inch) should be left in the top of the sterile bottle to facilitate shaking prior to analysis. Keep sample bottles closed until they are to be filled and be careful not to contaminate inside surfaces of containers. Fill containers without rinsing and cap immediately.

1. Remove aeration screen or other attachments from faucet.
2. If tap cleanliness is in doubt it may be cleaned with either an alcohol prep pad or a weak solution of Clorox bleach.
3. Run hot water first (if available) for 2-3 minutes then turn off. Run the cold water for 2-3 minutes.
4. Reduce water flow to permit filling bottle without splashing.
5. Fill sample container(s) with cold water and recap immediately.
6. Deliver samples to the laboratory as soon as possible.

Samples must be received at the laboratory within 24 hours of collection.

Do not take bacteria samples from a hose, they will almost certainly fail. Use a faucet that has been cleaned properly.

Special Instructions for Radon in Water or Volatile Organic Compounds:

If sampling for radon or volatile organic compounds, special vials are required. They must be filled so that there is a solid column of water (no air bubbles or head space) present after capping the vials. Invert the vial after filling and observe for any rising bubbles/air. If there are any bubbles/air, add more water. (Note: Radon in Air has separate instructions included in the kit – please follow those instructions.)

Label bottles with your name, address, date and time sampled.

Please fill in all information and include this sheet with samples.

MAILING INFORMATION (Please Print)

Name: Catherine Harrison
Street: 5 Longwood Drive
Town: Hopkinton
State/Zip Code: MA/01748
Contact Phone #: (508) 309-9254
Email: virtualmsharrison@gmail.com

call for
pmt

Payment is required when sample is received at lab.
We accept Cash, Check or Credit Card.
Results will not be released until payment is received

Do you have any water treatment devices? Yes

Are you having any problems with your water? No

****Test(s) To Be Performed**:** Must fill this line out for paperwork to be complete:

Hopkinton Regs
Comprehensive + NO RADON

Lab Use Only:
Temperature: 15.90
Evidence of Cooling? Yes: No: X Received by: JC Time: 1339 Date: 11/4/24

ALL RESULTS WILL BE EMAILED UNLESS OTHERWISE REQUESTED.
Please make sure you include your correct email address above.