

COUNTY PIN#: 0659-00-26-0322LOCATION#: 515-0107

- ☐ New
☐ Repair
☐ Re-Evaluation
☐ Addition/Expansion
☐ Non-Residential

RUTHERFORD-POLK-McDOWELL HEALTH DISTRICT IMPROVEMENT PERMIT

Valid for 5 Years from Date of Issue.

(Permit subject to revocation if site plans or intended use changes)

- ☐ Septic and Well ☐ IP ☐ CA
☒ Septic only ☒ IP ☒ CA
☐ Well Only ☐ IP ☐ CA

Applicant/Legal Agent: Street Seats Hot Rod Interiors / Arnold GisondaCounty: ☐ R ☐ P ☒ MCurrent Mailing Address: 4524 Needle Palm Dr.City: New Port RicheyState: FL Zip: 34652Property Location: 533 Catamba River Rd

Subdivision:

Lot#: Code:


Home Phone: 727-207-0006 Work Phone: 727-842-3351 Fax:

Agents Name & Phone#:

Directions to Property:

340 Awt to Old Fort Exit (72 at Cav Rd) under I-40 Bridge, immediate
on Catamba River Rd. to site on left (= 16010)Facility Type: AUTO UPHOLSTERY SHOP - 1 to 2 employees System Type: 11/25 septic Basement: ☐ Y ☒ N With Plumbing: ☐ Y ☒ NDesign Flow: 100 gpd L.T.A.R.: 3 gpd/ft² Septic Tank: 1000 gal Pump Tank: galNumber of Trenches: 2 Trench Length: 0 3 ft. Trench Width: 3 ft. Maximum Trench Depth: 18" in.Water Supply: ☐ Private Well ☒ Public/Comm. ☐ Spring ☐ Other: Well Variance: ☐ Y ☒ N (on lower side wall)S.T.: ☐ Y ☒ N Lot Size: 43 acresRepair System Type: 11/25L.T.A.R.: 3 gpd/ft²Design Flow Basis: 100 gpd misc. design Comments/Conditions: DO NOT GRADE OR FILL OVER DRAINFIELD AREAS.

SEE ATTACHED COMMENT SHEET

DIVERT SURFACE WATER 15' FROM SYSTEM PERIMETER.
☐ NOT DRAWN TO SCALE
link = 50 feet

*
 - No Floor
 DRAINS INTO
 SEPTIC SYSTEM

- BATHROOM
 CONNECTION ONLY

*NO INDUSTRIAL
 PROCESS (OILS, ANTIFREEZE, GASOLINE, PAINTS, ETC)
 WASTEWATER INTO SEPTIC SYSTEM

Improvement Permit Issued by: [Signature]

AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION

The wastewater system for the Improvement permit indicated above is hereby authorized. The wastewater system described in the improvement permit has been designed and can be installed and operated in accordance with Article 11 Chapter 130A of the General Statutes of N.C. and rules adopted pursuant to this article. Any alteration of the site or soil conditions, changes to the proposed facility to be served, or submission of information may subject the permit and authorization to suspension or revocation.

Wastewater System Construction Authorization: [Signature]R.S. Date: 6/8/15Date: 6/8/15

(VOID AFTER 5 YEARS)

AUTHORIZATION FOR WELL CONSTRUCTION

The well for the Improvement permit indicated above is hereby authorized. The well shall be located, constructed, and protected according to all applicable state and local rules and regulations. The well shall be installed and operated in accordance with Article 11 Chapter 130A of the General Statutes of N.C. and rules adopted pursuant to this article. Any alteration of the site or soil conditions, changes to the proposed facility to be served, or submission of information may subject the permit and authorization to suspension or revocation.